Officer of the PHC Sangwari, Rewari
Sanitation &Hygienic Certificate

Letter No/PHC /S/2025/ 45

Date: 10/06/2025

This is to certify that SMS International School Khijuri District Rewari was visited by health team. The team found hygiene and sanitation condition of the said school satisfactory.

This certificate is valid for one year.

10/06/2025

Medical Officer I/C
PHC Sangwari

Medical Officer
Incharge
PHC Sangwari

DISTRICT INTEGRATED PUBLIC HEALTH LABORATORY

District Hospital, Rewari

Water Bacteriological Report

D.No:- LAB/DCH/RWR/79/2025 Date:-05-06-2025

To,

M O incharge

PHC [redacted] SANGWARI

Subject:- Water sample report.

In reference to your Ref. letter PHC/S/2025/42 date 02-06-2025 which you have sent water sample for bacteriological examination, the result of samples are as under:-

S.No.:-	Place of collection	Result
1	SMS INTERNATIONATL SCHOOL KHIJURI	FIT
2	DELHI PUBLIC INTERNATIONAL SCHOOL MAJRA SHEORAJ	FIT

P.C.C: Presumptive coliforms count Sr. No 1,2 → 8/100ml, Satisfactory /class-2nd

Lab Technician
Civil Hospital, Rewari

Lab Incharge
Civil Hospital, Rewari

TC-11982

DISTRICT WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
GARHI BOLNI ROAD, REWARI, HARYANA

PHED Haryana

TEST REPORT

Test Report No.: - REW/03050/7/2025	Report Issue Date: - 09/07/2025
Customer Name: - SMS INTERNATIONAL SCHOOL	Sample Location: - Khijuri, Rewari
Customer's Address: - Khijuri, Rewari	Sample Collected by: - RAHUL
Your Reference No.: - Rewari PHESD No. 2	Sample Collected on: - 02/07/2025 11:03
Sample Type: - Chemical Test	Sample Received on: - 02/07/2025 12:18
Lab Job Order No.: - 03050	Sample Quantity: - 1 Liter

Test Result

Test started on: - 03/07/2025				Test completed on: - 03/07/2025		
Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable Limit	Permissible Limit
1	Turbidity	0.61	NTU	APHA 2130 B, 2024	1 NTU	5 NTU
2	Taste	Agreeable	---	IS 3025 (Part-8) 2024	Agreeable	Agreeable
3	Odour	Agreeable	---	IS 3025 (Part-5) 2024	Agreeable	Agreeable
4	Colour	1	Hazen Unit	APHA 2120 B, C, 2024	5 Hazen Unit	15 Hazen Unit
5	Total Dissolve Solids @ 180 ° C	98	mg/l	APHA 2540 C, 2024	500 mg/l	2000 mg/l
6	Total Hardness (as CaCO3)	50	mg/l	APHA 2340 C, 2024	200 mg/l	600 mg/l
7	Calcium as (Ca)	14.02	mg/l	APHA 3500-Ca B, 2024	75 mg/l	200 mg/l
8	Magnesium (Mg)	<10	mg/l	APHA 3500-Mg B, 2024	30 mg/l	100 mg/l
9	Total Alkalinity (as CaCo3)	70	mg/l	APHA 2320 B, 2024	200 mg/l	600 mg/l
10	Chlorides (as Cl)	40	mg/l	APHA 4500-Cl B, 2024	250 mg/l	1000 mg/l
11	Sulphate as (SO4)	22	mg/l	APHA 4500-SO4 D & E, 2024	200 mg/l	400 mg/l
12	Fluoride as (F)	0.36	mg/l	APHA 4500-F D, 2024	1.0 mg/l	1.5 mg/l
13	Iron as (Fe)	0.18	mg/l	APHA 3500-Fe B, 2024	1.0 mg/l	No Relaxation
14	Nitrate as (NO3)	3.8	mg/l	APHA 4500-NO3 B, 2024	45 mg/l	No Relaxation
15	pH @ 25 ° C	8.09	----	APHA 4500-H+ B, 2024	6.5-8.5	No Relaxation
16	Conductivity (at 25°C)	----	µS/cm	APHA 2510 B (Laboratory Method): 2017, 2024	----	----

Specific contractual notes: -

- The results given above are related to the sample as received and tested in PHED Lab Rewari.
- The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab Rewari.
- The test report can't be used for any publicity or any legal purpose.
- The samples received shall be destroyed after 7 Days from the date of issue of the certificate.
- Reliability of water sample lies with sender/collector of water sample.

Review & Authorised By

Authorised Signatory

Chemist
District Water Testing Lab
PHED, Rewari, Haryana

X----------End----------X